



# REPORT

issued by an Accredited Testing Laboratory

Contact person  
**Christian Mossberg**  
Energy Technology  
+46 10 516 59 13  
Christian.Mossberg@sp.se

Date  
2012-02-28

Reference  
PX14794A

Page  
1 (2)



Lindbergs Ventilation AB  
Västkustvägen 400  
254 77 FLENINGE

## Testing of Air Filter according to EN779:2002

(2 appendices)

An annual test according to CR055 (Certification rules for air filters) has been performed according to EN 779:2002.

The report of the production inspection is P800136-11.

### Tested item

Lindbergs Ventilation AB, F7 Microglas, art.nr 700150M10, 592 mm x 592 mm x 500 mm, 10 pocket air filter.

Lindbergs Ventilation AB, F7 Microglas, art.nr 700150M10, filter medium samples from a 592 mm x 592 mm x 500 mm, 10 pocket air filter (for discharging test).

The items were sent to SP by Lindbergs Ventilation AB and were received by SP on June 29, 2011.

The items were without visible defects.

### Date and Place

The test was carried out at SP's laboratory of Energy Technology in Borås, Sweden on February 15, 2012. Discharging test was carried out on February 16-20, 2012.

### Test method

The test was carried out according to standard EN 779:2002.

### Results

The results are presented in appendix 1 and are valid only for the items tested.

---

#### SP Technical Research Institute of Sweden

Postal address  
SP  
Box 857  
SE-501 15 BORÅS  
Sweden

Office location  
Västeråsen  
Brinellgatan 4  
SE-504 62 BORÅS

Phone / Fax / E-mail  
+46 10 516 50 00  
+46 33 13 55 02  
info@sp.se

Laboratories are accredited by the Swedish Board for Accreditation and Conformity Assessment (SWEDAC) under the terms of Swedish legislation. This report may not be reproduced other than in full, except with the prior written approval of the issuing laboratory.

## Measurement equipment

- Pressure gauge Furness FC016, SP's inventory no. 202 587 (static P Filter)
- Pressure gauge Furness FC016, SP's inventory no. 202 588 (static P Flow)
- Pressure gauge Furness FC012, SP's inventory no. 201 690 ( $\Delta P$  Filter)
- Pressure gauge Furness FC012, SP's inventory no. 201 691 ( $\Delta P$  Flow)
- Particle counter Las-X II, SP's inventory no. 701 378
- Auto sampler, SP's inventory no. 201 455
- Barometer, Druck DPI 260, SP's inventory no. 201 637
- Temperature and RH, Testo 635, SP's inventory no. 900 065
- Weighing scale, Mettler PC16, SP's inventory no. 202 741
- Flow meter, MFS-C-250, SP's inventory no. 202 742
- Flow meter, MFS-C50, SP's inventory no. 202 190
- Kr-85 Aerosol Neutralizer, TSI, SP's inventory no. 202 635

## Uncertainty of measurement

The uncertainty of the Air flow is better than  $\pm 5 \%$

The uncertainty of the Pressure Drop is better than  $\pm 3 \%$

The uncertainty of the Temperature is better than  $\pm 0.5 \text{ }^\circ\text{C}$

The uncertainty of the Relative Humidity is better than  $\pm 4 \%$  RH

The uncertainty of the Atmospheric Pressure is better than  $\pm 2 \text{ mbar}$

The uncertainty of the Measured mass is better than  $\pm 0.1 \text{ g}$

The method error in determination of the filtration efficiency is:

$\eta = 0\text{-}90 \%$ :  $\pm 0.1$  of penetration value [%]

$\eta = 90\text{-}99 \%$ :  $\pm 0.2$  of penetration value [%]

$\eta = 99\text{-}99.99 \%$ :  $\pm 0.5$  of penetration value [%]

$\eta > 99.99 \%$ :  $\pm 1$  of penetration value [%]

The uncertainty of the filtration efficiency according to EN 779:2002 is presented in the appendix.

## SP Technical Research Institute of Sweden Energy Technology - Combustion and Aerosol Technology

Performed by

Examined by

Christian Mossberg

Marie Rönnbäck

## Appendices

1. Test results according to EN779:2002

2. Picture of tested item

Appendix 1

Testing organisation: SP Technical Research Institute of Sweden Report no.: PX14794A

**EN 779:2002 AIR FILTER RESULTS**

GENERAL

Test no.: SP201202151	Date of test: 15/02/2012	Supervisor: CM
Test requested by: SP Technical Research Institute of Sweden		Device receiving date
Device delivered by: Lindbergs Ventilation AB		29/06/2011

DEVICE TESTED

Model: F7 Microglas, art.nr 700150M10	Manufacturer: Lindbergs Ventilation AB	Construction: Pocket filter, 10 pockets
Type of media: Glass	Net effective filtering area: 5.9 m <sup>2</sup>	Filter dimensions (width x height x depth): 592 mm x 592 mm x 500 mm


TEST DATA

Test air flow rate: 0.944 m <sup>3</sup> /s	Test air temperature: 23 to 33 °C	Test air relative humidity: 10 to 19 %	Test aerosol: DEHS	Loading dust: ASHRAE 52/76
--	--------------------------------------	---	-----------------------	-------------------------------

RESULTS

Initial pressure drop: 100 Pa	Initial arrestance: >99 %	Initial efficiency (0.4 µm): 62 %	Dust holding capacity: 213 / 276 / 311 g	Untreated/ discharged efficiency of media (0.4 µm, Annex A): 65 % / 57 %
Final pressure drop: 250 / 350 / 450 Pa	Average arrestance: >99% / >99% / >99%	Average efficiency (0.4 µm): 82% / 86% / 87%	Filter class (450 Pa): F7	Remarks:

Note: The performance results are only valid for the tested item and cannot by themselves be quantitatively applied to predict efficiency and lifetime in service



Appendix 1

**EN779:2002 - Efficiency after different dust loading phases**

Air filter: F7 Microglas, art.nr 700150M10  
 Test no.: SP201202151  
 Test aerosol: DEHS  
 Air flow rate: 0.944 m<sup>3</sup>/s

Particle size		Efficiency %									
Interval µm	Mean µm	Pressure drop, Pa and Dust fed, g									
		100 Pa 0 g	115 Pa 30 g	141 Pa 90 g	202 Pa 180 g	330 Pa 270 g	470 Pa 320 g				
0.10 - 0.12	0.11	49.5 ± 1.8	57.1 ± 1.2	68.3 ± 4.0	82.3 ± 1.3	90.6 ± 0.8	94.1 ± 0.5				
0.12 - 0.15	0.13	43.8 ± 0.7	55.2 ± 1.3	67.6 ± 1.3	81.3 ± 0.7	90.3 ± 0.6	93.6 ± 0.3				
0.15 - 0.20	0.17	44.8 ± 0.9	54.5 ± 1.0	67.1 ± 0.7	81.3 ± 0.6	90.9 ± 0.4	94.4 ± 0.3				
0.20 - 0.25	0.22	45.5 ± 1.9	57.3 ± 1.1	70.5 ± 0.5	83.7 ± 0.9	92.6 ± 0.4	95.4 ± 0.4				
0.25 - 0.35	0.30	52.6 ± 1.2	62.8 ± 1.0	75.0 ± 0.5	87.3 ± 0.5	94.6 ± 0.3	96.8 ± 0.1				
0.35 - 0.45	0.40	62.1 ± 0.6	71.8 ± 0.6	82.7 ± 1.0	92.2 ± 0.2	97.0 ± 0.3	98.3 ± 0.2				
0.45 - 0.60	0.52	72.6 ± 1.4	81.3 ± 0.6	89.7 ± 0.5	95.7 ± 0.4	98.6 ± 0.1	99.3 ± 0.1				
0.60 - 0.75	0.67	80.6 ± 1.6	87.4 ± 0.8	93.2 ± 0.9	97.8 ± 0.5	99.5 ± 0.2	99.7 ± 0.1				
0.75 - 1.00	0.87	86.7 ± 1.1	92.1 ± 0.9	96.5 ± 0.6	98.8 ± 0.4	99.8 ± 0.2	99.9 ± 0.1				
1.00 - 1.50	1.22	93.1 ± 0.8	95.9 ± 0.8	98.1 ± 0.3	99.5 ± 0.2	99.9 ± 0.1	99.9 ± 0.1				
1.50 - 2.00	1.73	96.9 ± 0.7	98.3 ± 0.4	99.2 ± 0.3	99.7 ± 0.1	99.9 ± 0.1	100.0 ± 0.1				
2.00 - 3.00	2.45	99.2 ± 0.6	99.7 ± 0.3	100.0 ± 0.0	100.0 ± 0.0	99.8 ± 0.4	100.0 ± 0.0				

NOTE The uncertainty of the measured efficiencies is reported on a 95 % confidence level.

**EN779:2002 - Average efficiency at different final pressure drops**

Air filter: F7 Microglas, art.nr 700150M10  
 Test no.: SP201202151  
 Test aerosol: DEHS  
 Air flow rate: 0.944 m<sup>3</sup>/s


Particle size		Average efficiency %		
Interval µm	Mean µm	Final pressure drop		
		250 Pa	350 Pa	450 Pa
0.10 - 0.12	0.11	69.8 ± 2.7	74.2 ± 2.1	76.3 ± 1.8
0.12 - 0.15	0.13	68.4 ± 1.3	73.0 ± 1.0	75.1 ± 0.9
0.15 - 0.20	0.17	68.2 ± 0.9	72.9 ± 0.7	75.2 ± 0.6
0.20 - 0.25	0.22	70.9 ± 1.0	75.4 ± 0.8	77.5 ± 0.7
0.25 - 0.35	0.30	75.4 ± 0.8	79.4 ± 0.6	81.3 ± 0.6
0.35 - 0.45	0.40	82.4 ± 0.7	85.6 ± 0.5	86.9 ± 0.5
0.45 - 0.60	0.52	88.9 ± 0.6	91.0 ± 0.5	91.9 ± 0.4
0.60 - 0.75	0.67	92.7 ± 0.9	94.2 ± 0.7	94.8 ± 0.6
0.75 - 1.00	0.87	95.7 ± 0.7	96.6 ± 0.5	97.0 ± 0.5
1.00 - 1.50	1.22	97.8 ± 0.5	98.3 ± 0.4	98.4 ± 0.3
1.50 - 2.00	1.73	99.0 ± 0.3	99.2 ± 0.3	99.3 ± 0.2
2.00 - 3.00	2.45	99.9 ± 0.2	99.9 ± 0.2	99.9 ± 0.2
Dust holding capacity		213 g	276 g	311 g
Filter class		-	-	F7

NOTE The uncertainty of the measured efficiencies is reported on a 95 % confidence level.

Appendix 1


**EN779:2002 - Efficiency after different dust loading phases**

Air Filter: F7 Microglas, art.nr 700150M10  
 Test no.: SP201202151  
 Test aerosol: DEHS  
 Air flow rate: 0.944 m<sup>3</sup>/s



**EN779:2002 - Initial and average efficiency at different final pressure drops**

Air Filter: F7 Microglas, art.nr 700150M10  
 Test no.: SP201202151  
 Test aerosol: DEHS  
 Air flow rate: 0.944 m<sup>3</sup>/s





Appendix 1

**EN779:2002 - Pressure drop and arrestance after different dust loading phases**

Air filter: F7 Microglas, art.nr 700150M10  
 Test no.: SP201202151  
 Test aerosol: DEHS  
 Air flow rate: 0.944 m<sup>3</sup>/s

Date	$\Delta p_1$	dm	$m_{tot}$	$\Delta p_2$	$m_1$	$m_2$	$\Delta m$	$m_d$	A	$A_m$
	Pa	g	g	Pa	g	g	g	g	%	%
15/02/2012	100	30	30	115	2610.5	2610.5	0.0	0.0	100.0	100.0
15/02/2012	114	60	90	141	2610.5	2610.5	0.0	0.0	100.0	100.0
15/02/2012	140	90	180	202	2610.5	2610.5	0.0	0.0	100.0	100.0
15/02/2012	201	90	270	331	2610.5	2610.5	0.0	0.0	100.0	100.0
15/02/2012	328	50	320	470	2610.5	2610.5	0.0	0.0	100.0	100.0

Symbols and units

- A arrestance, %
- $A_m$  average arrestance, %
- dm dust increment, g
- $\Delta p_1$  pressure drop before dust increment (air density 1.20 kg/m<sup>3</sup>), Pa
- $\Delta p_2$  pressure drop after dust increment (air density 1.20 kg/m<sup>3</sup>), Pa
- $m_d$  dust in duct after device, g
- $m_1$  mass of final filter before dust increment
- $m_2$  mass of final filter after dust increment
- $m_{tot}$  total mass of dust fed to filter, g
- $\Delta m$  mass gain of final filter, g

**Mass of tested item:**

Clean filter:	2 524.8 g
After complete test:	2 837.4 g

**Test dust**

ASHRAE 52/76, Particle Technology Ltd.  
 Batch no: 7681

Appendix 1

**EN 779:2002 - Efficiency and pressure drop of untreated filter material**

Air filter: F7 Microglas, art.nr 700150M10  
 Test no.: SP201202161  
 Test aerosol: DEHS  
 Discharging method: Isopropanol  
 Air flow rate: 14.8 l/s  
 Media velocity: 0.16 m/s  
 Size of material sample: 924 cm<sup>2</sup>

Particle size µm		Sample 1	Sample 2	Sample 3	Average
		Efficiency %			
Interval	Mean	Pressure drop			
		79 Pa	82 Pa	81 Pa	81 Pa
0.10 - 0.12	0.11	45.2 ± 4.8	48.4 ± 1.7	50.0 ± 8.7	47.8
0.12 - 0.15	0.13	41.0 ± 2.3	47.9 ± 1.5	48.6 ± 2.1	45.8
0.15 - 0.20	0.17	41.6 ± 2.0	46.1 ± 1.6	47.2 ± 1.5	45.0
0.20 - 0.25	0.22	44.2 ± 2.6	48.7 ± 2.4	50.4 ± 1.4	47.8
0.25 - 0.35	0.30	52.3 ± 2.7	56.0 ± 1.7	56.2 ± 0.8	54.8
0.35 - 0.45	0.40	62.6 ± 1.4	65.7 ± 1.2	67.2 ± 1.0	65.2
0.45 - 0.60	0.52	72.6 ± 1.3	76.7 ± 1.7	76.7 ± 0.9	75.3
0.60 - 0.75	0.67	81.0 ± 1.6	83.6 ± 0.9	84.0 ± 1.7	82.9
0.75 - 1.00	0.87	88.2 ± 1.0	89.0 ± 0.7	90.6 ± 0.8	89.3
1.00 - 1.50	1.22	92.6 ± 0.9	94.6 ± 0.8	94.6 ± 0.5	93.9
1.50 - 2.00	1.73	97.2 ± 0.6	97.6 ± 0.6	97.4 ± 0.3	97.4
2.00 - 3.00	2.45	99.5 ± 0.6	99.6 ± 0.3	99.4 ± 0.4	99.5

NOTE The uncertainty of the measured efficiencies is reported on a 95 % confidence level.

**EN 779:2002 - Efficiency and pressure drop of discharged filter material**

Air filter: F7 Microglas, art.nr 700150M10  
 Test no.: SP201202161  
 Test aerosol: DEHS  
 Discharging method: Isopropanol  
 Air flow rate: 14.8 l/s  
 Media velocity: 0.16 m/s  
 Size of material sample: 924 cm<sup>2</sup>

Particle size µm		Sample 1	Sample 2	Sample 3	Average
		Efficiency %			
Interval	Mean	Pressure drop			
		69 Pa	73 Pa	72 Pa	71 Pa
0.10 - 0.12	0.11	43.2 ± 4.3	46.8 ± 4.9	44.9 ± 4.8	45.0
0.12 - 0.15	0.13	41.0 ± 1.7	41.3 ± 2.4	40.3 ± 2.3	40.9
0.15 - 0.20	0.17	39.8 ± 2.1	39.8 ± 2.6	39.6 ± 2.2	39.7
0.20 - 0.25	0.22	42.2 ± 2.2	43.7 ± 2.1	41.5 ± 1.1	42.5
0.25 - 0.35	0.30	46.9 ± 1.6	48.7 ± 1.8	47.1 ± 1.4	47.6
0.35 - 0.45	0.40	55.8 ± 1.7	58.0 ± 1.7	56.5 ± 1.6	56.8
0.45 - 0.60	0.52	66.1 ± 1.1	68.5 ± 1.6	68.0 ± 1.0	67.5
0.60 - 0.75	0.67	74.5 ± 1.7	77.4 ± 1.7	75.3 ± 1.9	75.8
0.75 - 1.00	0.87	82.3 ± 1.5	84.9 ± 1.1	84.1 ± 1.0	83.8
1.00 - 1.50	1.22	89.7 ± 1.6	91.0 ± 1.6	91.4 ± 1.0	90.7
1.50 - 2.00	1.73	94.4 ± 0.6	95.5 ± 0.6	95.4 ± 0.7	95.1
2.00 - 3.00	2.45	99.2 ± 0.4	99.2 ± 0.3	99.2 ± 0.6	99.2

NOTE The uncertainty of the measured efficiencies is reported on a 95 % confidence level.



## Appendix 2

